

Fire Alarm System Standard Documentation Table and Check List

Bill of Material used for Fire Alarm System

Item No	Item Description	Qty	Remarks
1	Addressable Multisensor	160	
2	Addressable Manual Call Point	22	
3	Addressable Sounder Beacon	15	
4	Addressable Talkback Speaker	5	
5	Addressable Horn Speaker	2	
6	Addressable Monitor Module	4	
7	Addressable Control Module	2	
8	Addressable Short Circuit Isolator	8	
9	Addressable Control Panel	1	
10	Beam Detector	4	
11	Control Panel	1	

Check List for Fire Alarm Zonal details

Fire alarm systems installed in a building shall be divided into zones. List of zone number and zone description table.

ZONE ID	ZONE DISCRPTION	REMARKS
4	Left Fourth Floor	
12	Basement Store Room	
29	Right Ninth Floor	
32	Right Basement	

Checklist To verify Device ID, device location, Zone No, Zone Location and Its Function

DEV ID	DEV TYPE	DEV LOCATION	ZONE ID	ZONE LOCATION	Remarks
7	MANUAL CALL POINT	DENODO TECHNOLOGIES	6	SIXTH FLOOR CONFERENCE ROOM	
30	PA SPEAKER	ISOROUT BUSINESS CENTER	5	FIFTH FLOOR MEETING HALL	
35	Talkback SPEAKER	STAR INDIA	8	EIGHTH FLOOR DISCUSSION ROOM	
102	SMOKE DETECTOR	LIFT LOBBY	30	GROUND FLOOR LOBBY	

Check List for Sounder/Speaker Configuration

Speakers/Sounders are installed for the purpose to alert the occupants who are in danger zone also to alert support staffs who are responsible to support emergency. Hence audio system configuration detail document required to check the system

Device ID

Device Type

Device Location

S.No	Zone No	Zone Description	Remarks
1	11	GROUND FLOOR WAITING AREA	
2	29	NINETH FLOOR ELECTRICAL ROOM	
3	12	BASEMENT STORE ROOM	
4	8	EIGHTH FLOOR DISCUSSION ROOM	

Automatic Activation of Pre-recorded of voice alarm message based on zonal Output device location

S.No	Zone No	Zone Description	Pre-Recorded Voice Alarm Message	Remarks
1	29	Ninth Floor Electrical Room	Attention Please Fire Reported in Ninth Floor Electrical Room	
2	12	Basement Store Room	Attention Please Fire Reported in Basement Store Room	
3	8	Third Floor Discussion Room	Attention Please Fire Reported in Third Floor Discussion Room	
4	11	Second Floor Record Room	Attention Please Fire Reported in Second Floor Record Room	